


REPORT

TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING

14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUELABS

CLIENT Douglas Aircraft Company
Internal Mail Code 211-46
3855 Lakewood Boulevard
Long Beach, California 90846
Attention: Kathleen Faretta

DATE February 21, 1990

RECEIVED January 31, 1990

SAMPLE Monthly Storm Drain Inspection - January, 1990
P.O. No.: T & M 23465C

LABORATORY NO. 35853

INVESTIGATION As requested by the CRWQCB for NPDES permit numbers
CA0001406 and CA0001414

RESULTS

A representative of Truesdail Laboratories, Inc., tested the storm drain discharge on January 31, 1990, at the Douglas Long Beach facility (003) and Torrance facilities. The discharge was tested for flow rate, pH, and temperature. The results are as follows:

<u>Sample I.D.</u>	<u>Date</u>	<u>Time</u>	<u>Flow-gpd</u>	<u>Temp, °F</u>	<u>pH, units</u>
Long Beach (003)	1/31/90	10:05	123,149	54	8.0
Torrance	1/31/90	11:45	380	57	7.4

Respectfully submitted,
TRUESDAIL LABORATORIES, INC.

Luis Perez, Supervisor
Industrial Waste